



HESNI Spring Conference '24

Children's Wisconsin Facility Condition Assessment & Energy Master Plan

May 3, 2024

Introductions



Matt Cale, PE, CxA, LEED AP BD+C

National Program Manager at Farnsworth Group

- **20 years** of experience including commissioning for various healthcare clinics and campuses across the US.



Michael Gorham, MSOM, CHFM, CHC, NICET

Director of Facilities Management at Children's Wisconsin

- Engineering professional with progressive experience in facilities management, project management, budget development and staff management in the healthcare industry.




Jeff Boyer, LEED AP

Section Manager at Farnsworth Group

- **19 years** of experience including 17 years of experience in healthcare design and commissioning.

Agenda

- Overview/Introduction
- Facility Condition Assessment (FCA)
 - Approach
 - Results
 - Next Steps
- Energy Master Plan
- Energy Project Case Study



Needs Driven RFP

- The project was requested to:
 - Benchmark the performance and condition of the facilities
 - Quantify the budget gap using third party Licensed Professionals
 - Enable a more strategic and targeted annual budgeting process
- An Owner's Program Requirements Workshop was conducted to:
 - Further refine needs into scope
 - Right size the sampling and assumptions
 - Leverage the prior knowledge to avoid duplicated efforts
 - Define what a successful effort looks like

SCOPE OF SERVICES

Facility Condition Assessment
Owner's Program Requirements Workshop

Children's Wisconsin

March 29, 2023

Begin with the End in Mind



Facility Condition Assessment



What do we have?



Where should we spend our next maintenance dollar?



What condition is it in?



How do we move our program forward?



What needs to be done?


Asset Management: Building Your Capital Planning Model

Build Sustainment Model

Through phases 1-3 Farnsworth Group will work with client to build a sustainment model.

Analysis & Interpretation of Assessment

Through phases 4-6 Farnsworth Group will continue to train clients how to manage the sustainment model.



1 – PLANNING

- Project kick-off meeting Approach
- Overview of software
- Refine parameters, priorities, and schedule



2 – PRE-ASSESSMENT

- Coordinate with sites (access, resources, schedule)
- Configure software and systems
- Review systems and equipment categories



3 – ASSESSMENT

- Kick-off meeting at site
- Farnsworth Group & client site representatives for known information and site walks
- Visual assessment
- Out-brief meeting



4 – POST ASSESSMENT

- Collate data and results
- Quality review of data
- Baseline data review with client
- Review preliminary FCI, SCI, and capital forecast



5 – BUDGET MODEL & PRIORITIZATION

- Review ranking prioritization strategy and future capital budget with client
- Develop prioritized budget list based on client's strategy
- Review future FCI impact to facilities based on proposed budget
- Refine and adjust the model



6 – SUSTAIN (YEAR-OVER-YEAR)

- Planning for future fiscal year projects
- Develop project scopes, bundling and construction cost estimates
- Adjust model with project developed costs
- Update database with completed FY projects (as completed)
- Update database with actual construction costs
- Execute fiscal year budget projects

Standard Industry Approach

- Deferred Maintenance
 - The practice of postponing maintenance activities such as repairs or replacement on real property to save costs, meet budget funding levels, or realign available budget.

- Facility Condition Index (FCI)

$$FCI = \left(\frac{\text{Total Facility Deferred Maintenance Cost (\$)}}{\text{Facility Replacement Value (\$)}} \right)$$

- System Condition Index (SCI)

$$SCI = \left(\frac{\text{Total System Deferred Maintenance Cost (\$)}}{\text{System Replacement Value (\$)}} \right)$$

- Energy Use Intensity (EUI)

- EUI is the amount of utilities consumed per square foot. Used as a benchmarking metric.



Customized Approach

- Facility Condition Assessment
 - 7 facilities – 1.7M square feet
- Performed visual observations
- Collaborated with Childrens O&M team
- Goals
 - Identify condition of facilities and systems
 - Model future facility needs
 - Prioritize where next infrastructure dollar is spent (risk management).



Infrastructure Assessment Scope

- HVAC Air Systems
- HVAC Water Distribution Systems
- HVAC Controls
- Emergency Power
- Normal Power
- Plumbing
- Medical Gas
- Elevators
- Architectural Shell
- Architectural Finishes



RESULTS: FACILITY OVERVIEW

SKYWALK BUILDING
FCI: 0.00
DEFERRED MAINTENANCE: --
EUI: TBD

CLINICS BUILDING
FCI: 0.18
DEFERRED MAINTENANCE: 18.6 million
EUI: 104.6

YABUKI TOWER
FCI: 0.01
DEFERRED MAINTENANCE: 1.2 million
EUI: 149.2


WEST TOWER
FCI: 0.07
DEFERRED MAINTENANCE: 17.7 million
EUI: 208.3

CORPORATE CENTER
EUI: 162.3

CENTER TOWER
FCI: 0.18
DEFERRED MAINTENANCE: 37.6 million
EUI: 240.3

EAST TOWER
FCI: 0.17
DEFERRED MAINTENANCE: 27.3 million
EUI: 275.3

SOUTH TOWER
FCI: 0.36
DEFERRED MAINTENANCE: 14.5 million
EUI: 240.3



Facility Summary

| Facility | Year Constructed | Age | Size (Sqft.) | Facility Replacement Value | Facility Replacement Value (\$/Sqft.) | Deferred Maintenance (2024-2029) | Facility Condition Index | Facility Rating |
|-----------------------|------------------|-----|--------------|----------------------------|---------------------------------------|----------------------------------|--------------------------|------------------|
| South Tower | 1988 | 36 | 68,872 | \$ 41,112,063 | \$ 597 | \$ 14,598,207 | 0.36 | Fair / Poor |
| Center Tower | 1988 | 36 | 362,624 | \$ 207,287,350 | \$ 572 | \$ 37,621,029 | 0.18 | Good / Fair |
| Clinics Building | 1994 | 30 | 181,793 | \$ 104,574,318 | \$ 575 | \$ 18,606,272 | 0.18 | Good / Fair |
| East Tower | 1988 | 36 | 269,446 | \$ 161,288,577 | \$ 599 | \$ 27,375,711 | 0.17 | Good / Fair |
| West Tower | 2008 | 16 | 447,980 | \$ 242,613,135 | \$ 542 | \$ 17,759,085 | 0.07 | Excellent / Good |
| Yabuki Tower | 2020 | 4 | 232,590 | \$ 135,372,032 | \$ 582 | \$ 1,200,000 | 0.01 | Excellent |
| Skywalk Building | 2023 | 1 | 152,552 | \$ 93,755,408 | \$ 615 | \$ - | 0.00 | Excellent |
| Total/Average: | | 23 | 1,715,857 | \$ 986,002,884 | \$ 583 | \$ 117,160,304 | 0.12 | Good |

- Facilities generally in good condition.
- Maintenance is being performed very well.
- Strong O&M knowledge of equipment, systems, and operations.
- Values are aligned with observed conditions.

Risk Assessment

- Worked with Children's O&M staff to incorporate the current risk matrix strategy.
- Developed a prioritized deferred maintenance strategy.

Risk Categories

(decreasing priority)

1. Children's Risk Matrix
2. Deficiency Category
3. Deficiency Priority
4. System Condition Rating

| Facility Condition Index Scale | |
|--------------------------------|--------------------------|
| Facility Condition Index (FCI) | Condition Rating |
| FCI = 0.0 | New Facility |
| $0.00 > \text{FCI} \leq 0.10$ | Excellent Condition |
| $0.10 > \text{FCI} \leq 0.20$ | Good Condition |
| $0.20 > \text{FCI} \leq 0.35$ | Fair Condition |
| $0.35 > \text{FCI} \leq 0.50$ | Poor Condition |
| $\text{FCI} > 0.50$ | Extremely Poor Condition |


Target FCI: 0.10

Modelled Capital Forecast by Facility and Budget Year

| Facility | 2025 | 2026 | 2027 | 2028 | 2029 | Total |
|------------------|---------------------|---------------------|---------------------|---------------------|---------------------|----------------------|
| South Tower | \$ 1,326,000 | \$ 1,089,000 | \$ 1,289,000 | \$ 1,320,000 | \$ 1,293,000 | \$ 6,317,000 |
| West Tower | \$ 352,000 | \$ 383,000 | \$ 450,000 | \$ 324,000 | \$ 437,000 | \$ 1,946,000 |
| Clinics Building | \$ 1,291,000 | \$ 1,263,000 | \$ 904,000 | \$ 1,256,000 | \$ 713,000 | \$ 5,427,000 |
| Center Tower | \$ 1,971,000 | \$ 1,824,000 | \$ 2,096,000 | \$ 2,287,000 | \$ 2,356,000 | \$ 10,534,000 |
| East Tower | \$ 1,982,000 | \$ 1,305,000 | \$ 1,650,000 | \$ 1,700,000 | \$ 2,347,000 | \$ 8,984,000 |
| Yabuki Tower | \$ - | \$ - | \$ - | \$ - | \$ - | \$ - |
| Skywalk Building | \$ - | \$ - | \$ - | \$ - | \$ - | \$ - |
| Total: | \$ 6,922,000 | \$ 5,864,000 | \$ 6,389,000 | \$ 6,887,000 | \$ 7,146,000 | \$ 33,208,000 |


- FCI target of 0.10 for each individual facility
- Addresses deferred maintenance spending at the facility level
- No spending forecast for Yabuki and Skywalk (newer construction)

Yabuki – 20 Year Capital Forecast – Deferred Maintenance



Next Steps

- Leverage the study to inform the 2025 Budget
- Update 2023/2024 competed projects
- Identify 2025 projects to inform Children’s budget
- Sustainment Plan for FCA program



| 2023-2024 | DEVELOP | 2025 | IMPLEMENT | 2026 | SUSTAIN |
|-----------|--|------|--|------|---|
| | + Planning + Assessments + 2025 budget cycle + 2025 projects + Update database | | + Capital project execution + Update database + 2026 budget + 2025 projects | | + Capital project execution + Update database + 2027 budget + 2027 projects + Assessment + Measure |

Energy Master Planning




Key Takeaways:

- Overall energy use **decreased** by 9.7% from 2022 to 2023.
- Overall energy spending **increased** by approximately \$500k.
- Base Charges for Chilled Water and Steam drive spending.
 - A consumption only billing structure should be explored to translate energy savings into cost decreases. This policy is already in effect for Yabuki and Skywalk.
- Electrical focused projects offer the best cost reduction.
- Corporate Center offers the largest opportunity for improvement.

| 2022 Energy Use, Cost, & Performance | | | |
|--------------------------------------|--------------|----------------------|----------------|
| | EUI | Total Cost | EUI vs. Target |
| Clinics | 86.0 | \$ 785,189 | 183% |
| Yabuki | 179.7 | \$ 1,214,190 | 127% |
| West | 260.5 | \$ 2,974,734 | 183% |
| East | 301.1 | \$ 2,546,379 | 212% |
| Center | 243.0 | \$ 2,597,852 | 171% |
| South | 243.0 | \$ 493,402 | 171% |
| Corporate | 167.1 | \$ 1,283,779 | 309% |
| Total | 221.3 | \$ 11,895,524 | 185% |



| 2023 Energy Use, Cost, & Performance | | | |
|--------------------------------------|--------------|----------------------|----------------|
| | EUI | Total Cost | EUI vs. Target |
| Clinics | 104.6 | \$ 762,125 | 223% |
| Yabuki | 149.2 | \$ 1,109,650 | 105% |
| West | 208.3 | \$ 3,109,570 | 147% |
| East | 275.3 | \$ 2,546,961 | 194% |
| Center | 240.3 | \$ 2,860,615 | 169% |
| South | 240.3 | \$ 543,307 | 169% |
| Corporate | 162.3 | \$ 1,546,557 | 301% |
| Total | 201.3 | \$ 12,478,786 | 168% |

Energy Master Planning



Importance of Swimming Your Own Race

- Every project is unique! Constraints and opportunities
- Benchmarking is a valuable effort in providing context to EUI numbers, compared to peers.
- Tools such as EnergyStar Portfolio Manager can be used to statistically rank performance.
 - Weather normalization
 - Grid region/Utility carbon emission factors.
 - Population/Schedule/MRIs/Etc.
- BUT, Benchmarking is not everything...
 - Built-in utility plan capital amortization as a base charge significantly skews ROI
 - Reliance on a district system limits multiplier effects on EEMs
 - Only control over the demand-side of the equation
 - Legacy Building Automation Systems can limit EEM deployment.
 - In initial hurdle investment may be required to enable future ROI



Standards, Methods and Tools

- Formal Methods
 - IPMVP – International Performance Measurement and Verification Protocol
 - ASHRAE Level 1, 2 & 3 Energy Audits
 - NREL Strategic Energy Management (SEM) Evaluation Protocol
 - EnergyStar/ASHE Energy-To-Care
- Agile Approach – Embrace the 80/20 rule
 - High-level sweep across the portfolio to identify outliers annually.
 - Time/weather dependent audit of specific buildings/zones looking for correlations.
 - Correlation != causality, test interventions and concurrently assess feedback
 - 80% of the outcome (EUI deviation) will likely result from 20% of the causes.
 - Don't hesitate to utilize light-weight energy models (interdependencies)



Fast and "easy" wins




- Outside Air Flow exceeding ASHRAE 170/62.1 ventilation rates (can be exhaust driven)
- Economizer operation at night with radiant reheat feedback
- AHUs “stuck” in dehumidification mode
- DAT control and MAT control
- Rogue zone suppression
- Parallel VAV reheat and perimeter radiant control
- Deadband relaxation, PID tuning
- Seemingly easy, but not necessarily easy:
 - Unoccupied setback
 - Lighting control

| | | | |
|---|--------------------|--------------|--|
| ● | WARMUP | Disable | Warmup Command Status |
| ● | 1CClg-T | 59.0 deg F | Cooling Coil Discharge Air Temp |
| ● | DA-T | 60.2 deg F | Discharge Air Temp |
| ● | DAT-STPT | 59.7 deg F | Discharge Air Setpoint |
| ● | MA-T | 48.6 deg F | Mixed Air Temp |
| ● | DA-H | 18 %RH | Discharge Air Humidity |
| ● | DAHUM-LMT | 2.0 deg F | Discharge Humidity Limit Setpoint |
| ● | RA-T | 71.9 deg F | Return Air Temp |
| ● | RA-H | 25 %RH | Return Air Humidity |
| ● | CHS-T | 56.7 deg F | CHW Supply Temp |
| ● | CHR-T | 68.3 deg F | CHW Return Temp |
| ● | OA-FLOW | 17.656 cfm | Outdoor Air Flow (kCFM) |
| ● | OAFSPT | 7.863 cfm | Outdoor Air Flow Setpoint (7.965) |
| ● | CLG-VLV | 0 % | Cooling Coil Valve |
| ● | RH-VLV | 0 % | Reheat Coil Valve |
| ● | HTG-VLV | 0 % | Heating Coil Valve |
| ● | OA-DPR | 52 % open | Outdoor Air Damper |
| ● | RA-DPR | 43 % clos... | Return Air Damper |
| ● | EA-DPR | 43 % open | Exhaust Air Damper |
| ● | ECON | Free | Economizer Mode |
| ● | AHU-1A RA Enthalpy | 21.8 Btu/lb | Return Air Enthalpy |
| ● | OA Enthalpy | 14.4 Btu/lb | Outside Air Enthalpy |
| ● | HCP1-S | Off | Heating Coil Pump Status |
| ● | MAPInSP | 0.036 in wc | MA Plenum Static Press (Across RA-Dpr) |
| ● | PF-DP | 0.10 in wc | Pre Filter Diff Press |
| ● | FF-DP | 0.17 in wc | Final Filter Diff Press |
| ● | ZN-H | 26 %RH | Air Handler Zone Humidity |
| ● | HUM-SPT | 26 %RH | Zone Humidity Setpoint resets(20-26) |
| ● | HUM-VLV | 12 % open | Humidifier Valve |


Slide 21

MC0 Pull a better picture
Cale, Matt, 2024-04-23T18:18:00.980



KPI Reporting Accessibility




CAMPUS REPORT



Energy Report Card Tracking



Accounting For Construction




Energy Awareness in Cx -> FACOPS

- Excess Heating Air Flow Setpoints
 - 7870 CFM above min flow
 - Estimated +\$6572 annual fan electricity
- Excess ACH over ASHRAE 170
 - 2948 CFM above
 - +\$2462 annual fan electricity
 - +\$2312 annual steam consumption
 - +\$8788 annual chilled water consumption
- Total potential cost avoidance: \$0.67 psf
- Center tower baseline: \$1.90 psf
- No schedule impact. Follow-up in ops.



EnergyStar Targets Met or Exceeded

Current




EnergyStar Progress



HOSPITAL

75 MINIMUM REQUIRED SCORE FOR CERTIFICATION



Key Results

- Identified an expected \$8.2M budget deficit over five years
- Prioritized a master project list
- Created a database the Owner can manage independently and update over time
- Submitted for the ASHE Energy to Care Award
- Joint Commission Sustainable Healthcare Organization Certification
- Served Children's Core Value
 - Innovation - We commit to improvement with breakthrough ideas and solutions.



The text "Q&A - Discussion" is displayed in a white, serif font on a green background. The background of the entire slide is a photograph of a modern operating room with surgical lights, a table, and cabinets, overlaid with a blue and green gradient.

Q&A - Discussion